



OFFICE OF THE DISTRICT FIRE OFFICER
SARJAPUR ROAD FIRE STATION
KAIKONDRAHALLI BANGALORE-560 035.



Email:dfosarjapur99@gmail.com

Telephone No: 080-25746123

C.NO: 46/DFO/SRFS/BNG/2022.

OFFICE OF THE DISTRICT FIRE OFFICER
Karnataka State Fire & Emergency Services
Sarjapura Road Fire Station
Bangaluru-560 035.

Date: 21/12/2022

"Annexure-2"

To,

The Authorized Signatory
M/s. NEMESIA ACADEMY,
Sy.No.73/New Sy.No.73/5,
Harohalli Village, Huskur P.O,
Bengaluru-560 099.

Sir,

Sub: Issue of "Fire Safety Compliance report" with respect to fire prevention, fighting and evacuation measures maintained at "M/s. NEMESIA ACADEMY, Sy.No.73/New Sy.No.73/5, Harohalli Village, Huskur P.O, Bengaluru-560 099".

Ref: 1) This office FSR No.46/Dfo/SRFS/Bng/FSR/2022. Dt:-15-12-2022.

2) Your request letter dated: 10-12-2022.

<<<>>>

With reference to the above cited subject, as per reference (1) a conditional Fire Safety Recommendation was issued to the premises of "M/s. NEMESIA ACADEMY Sy.No.73/New Sy.No.73/5, Harohalli Village, Huskur P.O, Bengaluru-560 099". with a Condition to fulfill the recommendations and compliance the same within 3 months,

With reference cited (2) above, the management of "M/s. NEMESIA ACADEMY" had requested for the fire safety compliance report from our department. In this regard the above addressed educational building was inspected by me on 12/12/2022 for issue fire safety Compliance report.

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing the **"Fire Safety Compliance Report"** to. "M/s. NEMESIA ACADEMY Sy.No.73/New Sy.No.73/5, Harohalli Village, Huskur P.O, Bengaluru-560 099". Subject to proper maintenance of fire fighting installations in the good working conditions and arrange for 40% of staffs/ employees training within 03 months from the date of issue of this report.

"This report is valid for one year from the date of issue of this report and is renewable

without fail.

Yours faithfully,

DISTRICT FIRE OFFICER
Sarjapura Road Fire Station
Bangaluru-560 035.